

McKean, Thomas

From: McKean, Thomas**Sent:** Tuesday, November 24, 2009 10:10 AM**To:** Traczyk, Art**Subject:** Comprehensive Permit Application / Proposed Development- Stage Coach Residences

Dear Mr. Traczyk,

I have reviewed the proposed project consisting of 18 bedrooms proposed to be located at the end of Stage Coach Road Centerville. Although I have no objections to this proposal, I submit the following comments:

- The proposed flow exceeds 1650 gallons per day. Therefore, under Section 360-37 of the Town of Barnstable Code, the Board may required a shared system consisting of innovative/alternative technology*. However, the Board of Health does not meet until later in December, after the ZBA meeting is scheduled regarding their review of this project.
- The designing engineer shall submit a completed seven page plan review checklist to the Public Health Division Office prior to obtaining a disposal works construction permit.
- The shared system shall be inspected every three years by a certified septic system inspector as required by the State Environmental Code, Title 5.
- The applicant shall provide information to the Board relative to the proposed frequency of disposal of the single dumpster shown on the plan.

Sincerely yours,

Wayne Miller, M.D.

DIVISION

2009 NOV 24 AM 10:30

TOWN OF BARNSTABLE